

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING – BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7125-1501:121

Page 1 of 1

**CATEGORY:** Fire Alarm Devices for the Hearing Impaired

**LISTEE:** Edwards Signaling, 8985 Towne Center Parkway, Badenton, FL 34202  
Contact: Jewell Micochero (941) 739-4358 FAX (941) 308-8123

**DESIGN:** Models EG1-HV15, -HV30, -HV60, -HV-75; EG1-HOV15, -HOV30, -HOV60, -HOV75, -HOV110; EG1F-HOV15, -HOV30, -HOV60, -HOV75, -HOV110; EG1RF-HOV15, -HOV30, -HOV60, -HOV75, -HOV110; EG1-HD, EG1R-HD, EG1F-HD, EG1RF-HD, EG1-HDVM, EG1R-HDVM, EG1F-HDVM, EG1RF-HDVM, EGC-HDVM, EGCF-HDVM, \*EGCFR-HDVM, EGC-HDVMH, EGCF-HDVMH, EG1-HDV1575, EG1R-HDV1575, EG1F-HDV1575, and EG1RF-HDV1575 horn/strobes with or without suffixes -R and -F. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Electrical: 24-30 VDC  
16-33 Vdc/Vfwr – Models EG1-HD, EG1R-HD, EG1F-HD, EG1RF-HD, EG1-HDVM, EG1R-HDVM, EG1F-HDVM, EG1RF-HDVM, EGC-HDVM, EGCF-HDVM, \*EGCFR-HDVM, EG1-HDV1575, EG1R-HDV1575, EG1F-HDV1575, and EG1RF-HDV1575  
Candela: 15cd, 30cd, 60cd, 75cd, 110cd  
15-95 multi-cd – Models EGC-HDVM, EGCF-HDVM and \*EGCFR-HDVM  
95-177 multi-cd – Models EGC-HDVMH, EGCF-HDVMH  
15/75cd – Models EG1-HDV1575, EG1R-HDV1575, EG1F-HDV1575, and EG1RF-HDV1575

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical/candela rating, and UL label.

**APPROVAL:** Listed as horn/strobe lights for use with separately listed compatible fire alarm control units. For indoor use and wall mount only. Also suitable for audible signal appliances. Models EGC-HDVM and EGCF-HDVM for ceiling mount only. Refer to listee's Installation Instruction Manual for details.

These horns can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.

**FORMERLY:** 7125-1388:231

**XL:** 7125-1591:202

\*Rev. 05-15-2007 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 29, 2008**

*Listing Expires June 30, 2009*

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*